



Mevr. Gerrie Ziemerink
TEN CATE TECHNICAL FABRICS BV
Postbus 8
NL-7440 AA NIJVERDAL
NEDERLAND

Your delivery of
2009-11-12

Your reference

our reference
PVH/243

date
Zwijnaarde, 2010-01-13

Certification report

valid for 5 years

1. Description of the tested article:

Applicant : Ten Cate Technical Fabrics bv
Postbus 8
NL-7440 AA NIJVERDAL
Nederland

Product description:

Quality name: TenCate Campschild™ - FR0001 Cover

Weight : 430 g/m²

No accelerated ageing

2. Executed tests:

NF P 92-503 (1995) - "Electric burner test"


French decree from 21 November 2002 - Reaction to fire tests on interior materials

Detailed results can be found in: Analysis report 71477 of 2009-11-20

3. Conclusion: Classification of the quality TenCate Campschild™ - FR0001 Cover

M1

4. Durability of this classification: Twelve months after installing in a building subjected to fire safety regulations


Pros Van Hoeyland
order responsible

This report runs to 1 pages and may be reproduced, as long as it is presented in its entire form, without written permission of Centexbel. The results of the analysis cover the received samples. Centexbel is not responsible for the representativeness of the samples.



VAT BE 0459.218.289
CENTEXBEL-GENT
Technologiepark 7
BE-9052 Zwijnaarde
Tel. + 32 9 220 41 51 • Fax + 32 9 220 49 55
e-mail gent@centexbel.be

Fin. Acc. 210-0472965-45

IBAN BE44 2100 4729 6545

CENTEXBEL-BRUSSELS
Montoyerstraat 24 B2
BE-1000 Brussels
Tel. + 32 2 287 08 30 • Fax + 32 2 230 68 15